BaSyTec MRS

Regenerative Battery Test System



Battery Cell and Module **Test System** up to 70V up to 1000A up to 14kW with energy recovery

saves energy / reduces heat generation

BaSyTec MRS Regenerative Battery Test System

Main Features

The BaSyTec MRS Regenerative Module Test System is a cost effective solution for the test of battery cells up to 900A (up to 2500A in parallel mode) or modules up to 70V/14kW and 570A (up to 36kW/1500A in parallel mode).

Because of the innovative switched design with energy recovery heat generation is much reduced which results in low working expenses. The discharged energy will be fed back into the grid.

Nevertheless the system offers high precision and speed and is controlled by the well known BaSyTest Software.

| | 7 - | 3 | 🍌 🔓 🔓 📙 E | | | <u> </u> | 4 | Er . |
|---|---------|--|-------------|-----------------------|-------------------------------|--|--------------|---|
| Į | Indo Tu | cal 3c 3c (2) (2) (2) (3) (4) (4) (4) (4) (4) (4) (4) (4) (4) (4 | | Registration-Format | Search | Context for channel <all channel=""></all> | | el> • |
| | Level | Label | Command | Parameter | Termination | Action | Registration | Comment |
| | | | Start | | | | | Terminate cycle life test if the battery capacity falls below 80% of initial capacity |
| | æ | | Calculate | C80=-8*As_D(DIS_1)/10 | | | | Calculate 80% of the battery capacity measured in line 4 As_D is always positive |
| | 1 | | Charge | I=0.5A | t>3h UMax-U>5mV | | t=10s | Charge the battery to 100% SOC |
| | • | DIS_1 | Discharge | I=8.25A | U<1.8V | | t=10s | Measurement of the reference capacity |
| | 9 | | Cycle-start | | | | | cycle with 100% dod |
| | 1 | | Charge | I=0.5A | t>3h UMax-U>5mV | | t=10s | Charge the battery to 100% SOC |
| | 0 | | Pause | | t>1min | | t=10s | |
| | • | | Discharge | I=0.25A | Ah <c80 U<1.0V</c80 | Goto Go_on Goto Eol | t=10s | Discharge 80% if not 80% reachd -> EOL |
| | • | GO_ON | Discharge | I=0.25A | U<1.0V | | t=10s | Go On discharging for 100% discharge |
| | 0 | | Pause | | t>1min | | t=1s | |
| | U | | Cycle-end | Count=10000 | | | | max. 10000 cycles |
| | • | EOL | Pause | | t>10s | | t=1s | EOL: End Of Life |
| | B | | Stop | | | | | |

Applications

- Parameter Tests
- Endurance Tests
- Abuse Tests
- BMS Tests

Technical Data

| Charge Voltage | 3-70V | 0-6V | | | |
|----------------------|-----------------------------|------------|--|--|--|
| Discharge Voltage | 3-70V | 1-6V | | | |
| Voltage resolution | 3mV | 200uV | | | |
| Voltage precision | 15mV | 1mV | | | |
| Meas. U | 4-wire | | | | |
| Current precision | 0.05% FS | | | | |
| Current ripple | < 0.3%FS | | | | |
| Current rise time | 1ms | | | | |
| Min. pulse length | 1m | ns . | | | |
| Current ranges | Optional, up to 3 | | | | |
| Range switching | automatic | | | | |
| Parallel operation | Up to 4 channels | | | | |
| Standard | Voltage | | | | |
| measurement | Current | | | | |
| | 2* Temperature Pt100/4W | | | | |
| | 2* Aux Voltage (+/-10V) | | | | |
| Time resolution | 1µs | | | | |
| Channel | 70A / 1.5kW | 100A | | | |
| configurations | 140A / 3kW | 200A | | | |
| | 210A / 4.5kW | 300A | | | |
| | 280A / 7kW | | | | |
| | 360A / 9kW | 600A | | | |
| | 500A / 12kW | 800A | | | |
| | 570A / 14kW | 1000A | | | |
| Control mode | Current (analog) | | | | |
| | voltage, power, resistance | | | | |
| | and combinations (digital) | | | | |
| Options | CAN Interface | | | | |
| | BSD (Battery Safety Device) | | | | |
| | CMU Cell Voltage Inputs | | | | |
| | CMU Type-K, Pt100/4W, NTC | | | | |
| | SSMS Interface | | | | |
| | Digital-IO | | | | |
| Cooling | Relay Outputs | | | | |
| Cooling | Air, temp regulated fans | | | | |
| Power Supply | 400V / 3 phases, N, GND | | | | |
| Power Factor | > 0.99 | Un to 000/ | | | |
| Efficiency Charge | Up to 90% | Up to 80% | | | |
| Efficiency Discharge | Up to 87% | Up to 70% | | | |
| Software | BaSyTest | | | | |
| Interface | Ethernet | | | | |

BaSyTec GmbH

Oellinger Weg 17, 89176 Asselfingen, Germany

Tel.: +49-7345/238 500, Fax: +49-7345/238 725, www.basytec.com Status: 03/2017